

ExxonMobil Pipeline Company
52 Beacham Street
Everett, MA
Phone: (617) 381-2872
Facsimile: (617) 381-2954

Michael K Butler
Field Environmental Advisor



September 7, 2011

VIA OVERNIGHT MAIL

Water Technical Unit (SEW)
U.S. Environmental Protection Agency
P.O. Box 8127
Boston, Mass. 02114

**RE: Submission of Discharge Monitoring Reports
Permit No. MA0000833**

Dear Sir/Madam:

On behalf of Exxon Mobil Corporation, ExxonMobil Pipeline Company is providing the attached submission to the United States Environmental Protection Agency (US EPA). The August 2011 sampling data has been submitted via the NetDMR system to the US EPA including the permit-required analytical reports for the following period:

- August 1 - 31, 2011 (monthly DMR)
 - Sampled from outfall 001A on August 2, 2011
 - There was no discharge from outfall 001B during the month of August 2011

Please note that the Total Suspended Solids (TSS) concentration reported from a single sample collected from Outfall 001A on August 2, 2011 was reported at a concentration of 32 mg/L. This value is significantly below the TSS daily maximum limit of 100 Mg/L; however, it is slightly above the monthly average permit limit of 30 mg/L and therefore has been reported as a monthly average exceedance on the NetDMR.

ExxonMobil Everett Terminal's Stormwater Pollution Prevention program includes an aggressive program of Best Management Practices with routine site inspections, structural controls and preventive maintenance activities to minimize solids runoff into stormwater drains throughout the terminal. The storm drain inserts used to capture solids are inspected and are replaced on a

routine basis. The terminal's Stormwater Pollution Prevention team will review current practices to determine if additional measures are warranted.

Please also note that Whole Effluent Toxicity (WET) testing will be performed in September 2011 in accordance with current permit (September 2008) requirements. It appears that the NetDMR is set up for reporting WET testing which was required in August by the previous permit (March 2000). Therefore, the LC50 entry includes a NODI code. September WET test results will be submitted in October.

If you have any questions, please contact me at (617) 381-2872.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael K. Butler". The signature is fluid and cursive, with the first name "Michael" being the most prominent.

Michael Butler
Field Environmental Advisor

cc: Mass. Dept. of Environmental Protection, Office of Watershed Management (DWM)
Mass. Dept. of Environmental Protection, Bureau of Waste Prevention